

Parametri pavimento fittizio

passo	Rq	qg
7,5	0,247	98,5
15	0,289	96,24
22,5	0,334	90,22
30	0,386	82,53

qa 85 watt

Curve caratteristiche

ΔT	p 7.5	p 15	p 22.5	p 30	qa
0	0	0	0	0	85
35	141,70	121,11	104,79	90,67	85

Curva limite

passo	qa	ΔT qa	qg	ΔT qg
7,5	85	21,00	98,50	24,33
15	85	24,57	96,24	27,81
22,5	85	28,39	90,22	30,13
30	85	32,81	82,53	31,86

ΔT min	21,00 °C	ΔT	ΔT max	q
ΔT max	28,39 °C	21,00	28,39	0
		21,00	28,39	85

Tm min 41,00 °C
Tm max 50,96 °C

Tm 46,0 °C

